



Sunnyvale Department of Public Safety

FIRE PREVENTION UNIT



**HOSE CABINETS**

-Hose Removal-

*(Internal)*

Hose connected to a Class II standpipe system shall comply with 905.5 CFC and other provisions of Chapter 9.

When not otherwise required, the following occupancies may remove the 1" fire hose from the cabinet. When removed, the exterior of the cabinet must be marked with a sticker or sign indicating, "**Fire Department Hose Valve**".

**B Occupancies** – authorized to remove hose

**R1, R2, Occupancies (automatic fire sprinklers)** – authorized to remove hose

**R1, R2, Occupancies (no automatic fire sprinklers)** – Hose must remain and be tested/changed according to current code.

**All other Occupancies (S, H, etc.)** - Hose must remain and be tested/changed according to current code.